

Lincoln County
City-County Board of Health Minutes
5:00 PM, July 2, 2024

- **Call to Order**
 - Jan, Amy, Kristin, Jim, Josh, Lannie and Patty present

- **Action Item** – Paul Dalziel Variance Request
 - Robin presented this variance request for a replacement system that is requesting a reduction of 30 lineal feet due to space limitations. The replacement would be pressure dosed and LCHD supports the variance request.
 - Jan motioned. Jim seconded. No public comment. All in favor. Motion passed.

- **Action Item** – Kody Green Variance Request
 - Robin explained that this variance started as a violation with surfacing sewage from a failed system. The proposed replacement drainfield is out of the neighbor’s well isolation zone and 75’ from Green’s well. The existing drainfield is only 65’ from Green’s well. This is an improvement and LCHD supports the variance request.
 - Kristin motioned, Jan seconded. Jan amended the motion to add that LCHD strongly recommends that the property owner test his water annually. Jim commented that the variance needs to be recorded on the property at the Clerk & Records office. No public comment. All in favor. Motion passed.

- **Public Comment**
 - None

- **Adjourn**