PERMIT

Issue Date: 6-16-93 Permit No. _____

Property Owner: JAMES & DOLORES KEIFFER c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: _____ License No. 24

X New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: Rhodes Island 10-13 S3T28R33

Address or Location: 16490 Bull Lk Rd

Approved Design Criteria:

Septic Tank Size: 1000 gallons Drainfield Size: 160 lineal feet

Special Instructions: Construct system as per lot layout and County wastewater Reg. #3 Sand lined drainfield required

Approved Site plan (Lot Layout) Attached


Issued By: Johnnie Peterson, RS

Closure Statement:

I, FRED McDONALD *have inspected this system and found it to be in compliance with the conditions of the permit and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Fred McDonald *Date:* 6/16/93 5/7/97

Title: McDonald Enterprises - owner


100±
Home
4" Line
DRYWELL
& Pump
1000 gal
TANK
100±
Raised 2 feet
Above "TOP K
2" solid
Line
Replacement
Site
DRIVEWAY
DRAIN FIELD
10'
80'
Distribution
Box

LOT LAYOUT