DEPARTMENT of ENVIRONMENTAL HEALTH
Wastewater Treatment and Disposal System
PERMIT

Issue Date: 08/05/99 Expiration Date: 08/06/00

Property Owner: Mark A. Laffoon c/o: Wayne Maffit

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: ~~Andy's~~ B-K Construction License No. [redacted] 75

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: SYSTEM WILL HAVE 1500 GALLON TANK, WITH 500-GALLON CHAMBER TO BE USED AS PUMP CHAMBER FOR LIFT STATION. RV DUMP HOOKUP TO BE INSTALLED.

Parcel Description:

Legal: S32 T29 R33 Upham Beach Lots 18W & 18E and S 1/2 19W & 19E

Address or Location: 15930 Bull Lake Road

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1500 gallons Drainfield Size: 220 lineal feet

INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ***LIFT STATION REQUIRED. DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: *Kendra I. Lind, R.S.*

Closure Statement:

I, Larry Bowman *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Larry Bowman *Date:* 5/18/00

Title: B-K Constr. Owner

LOT LAYOUT
MARK A. LAFOON
LOTS 18W AND 18E
S 1/2 OF LOTS 19W & 19E
UPHAM BEACH

