DRAINFIELD

~~SEPTIC TANK~~ PERMIT for LINCOLN COUNTY

Permit Sent MAY 6, 1978

Phone 3-7997

Date MAY 6, 1978

Property Owner LARRY PRINKKI Address P.O. Box 558 LIBBY

Lot, Block Number, or legal description of Property LOT 85 RAWLINGS TRACTS


To be built by: SMART Square feet absorption area. 260 sq.ft. (minimum

Septic Tank Size 1000 gal # of bedrooms 3 Water Supply WELL

Description of Absorption Area: Dig A ditch at least 130' in length x 2½-3' deep x 2' wide according to lot layout and ditch diagram Grade of pipe should not exceed 1% drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.

LOT LAYOUT



Issued by Ron Anderson Inspected by

Date May 8, 1978

well

(No scale)