PERMIT

Issue Date: 05/26/95 Expiration Date: 05/27/96

Property Owner: Margaret Slater c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: John Kampfe Construction License No. 15

XX New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Re-issue of 5-26-95 Rosalie Cleveland permit to correct name of property owner.

Parcel Description:

Legal: S33 T29 R33

Address or Location: Lot 24 Upham Beach Troy, MT

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 195 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: [signature], RS

Closure Statement:

I, John Kampfe, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.


Signed: John Kampfe Date: 7-21-95

Title: Installer

LOT LAYOUT

CLEVELAND

MAY 1995



LEGEND

- Soil Profile
- Perculation Site
- Proposed Septic Site and Replacement Site
- Slope
- Proposed Well Site

GRAPHIC SCALE

100 0 50 100 200 400

(IN FEET)

1 inch = 100 ft.