NEW HOUSE

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Phone [redacted] [redacted] Date 6-9-76

RT 2

Property Owner ~~Dean~~ STAN TALLMINDGE Address BULL LAKE Rd. - TROY

Lot, Block Number, or legal description of Property UPHAM BEACH LOT 1

S 6 32
T 29
R 33


To be built by: HALL Square feet absorption area. 250 sq ft.

Septic Tank Size 1000 gal of bedrooms 3 Water Supply well

Description of Absorption Area: Dig a ditch 125' in length x 2½-3' deep x 2' wide according to lot layout. Add at least 125' on drainfield as per lot layout addition

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.





Issued by Ron Anderson Inspected by _____

Date 6-9-76

Revised for drainfield extention
8/31/81
Johnnie Peterson, R.S.