PERMIT

Issue Date: 10/12/93 Permit No. _____

Property Owner: CAROL TONKYN c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: Kootenai Valley Contractors OWNER License No. 14

✓ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: _____

Parcel Description:

Legal: Lot 20' N 1/2 Lot 19 - UPHAM BENCH S32 T29 R33

Address or Location: BULL LAKE TROY, MT

Approved Design Criteria:

Septic Tank Size: 1000 gallons Drainfield Size: 250 lineal feet

Special Instructions: INSTALL SYSTEM ACCORDING TO LOT LAYOUT AND SEPTIC SYSTEM REGULATION

Approved Site plan (Lot Layout) Attached


Issued By: [signature] RS


Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: Bruce H Cole *Date:* 10-17-97

Title: _____


N
100 Yr flood zone
Drain Field:
5% slope
40° West of North
Pull Lake
Septic Tank
Pump Station
Garage
Pressure
62.5
Drain Field
Reserve
211
Soil Profile Hole
Perc Test hole
Perc 60
Driveway
Hwy 56
well
DOTTED LINE:
Underground Power Line to Pedestal


62.5
62.5
62.5
62.5
10
10
10
DISTRIBUTION Box
DRAINFIELD DETAIL