NEW WELLS

SEPTIC TANK PERMIT
for
LINCOLN COUNTY
Attn: Bob Stewart

Permit Sent ____

Date 7-27-79

Phone [redacted]

Property Owner ASARCO Address TROY MT


Lot, Block Number, or legal description of Property SE¼ Sec 26 T29N R34W
ASARCO MINE SITE

To be built by: M. Warrington Square feet absorption area. 300

Septic Tank Size 2-500gal # of bedrooms ___ Water Supply WELL OR Spring (at least 100' from drain fie

Description of Absorption Area: Dig a ditch 150' long x 2½-3' deep
x 2' wide according to lot layout and ditch diagram
Slope of pipe should not exceed a 1" drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Issued by John W Peterson Inspected by ____

Date 7-27-79

This drain field system will be capped & Tile removed. It may be used for groundwater