NEW

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Phone _____

Date 3-30-79

Property Owner Clyde Beck Address Angel Island


Lot, Block Number, or legal description of Property Block 5 Lot 22

To be built by: M. Warrington Square feet absorption area. 450

Septic Tank Size 1000 gal # of bedrooms 3 Water Supply Community


Description of Absorption Area: Construct a seepage bed according to the lot layout and the attached sheet. Drainpipe should have no slope.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

LOT LAYOUT



SOIL: tight silt fill

SLOPE: 0%

Issued by John W Peterson Inspected by _____

Date 3-30-79