NEW

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent 8-30-76

Date 8-30-76

Phone —

Property Owner A.P. BRACEBUSH Address [redacted]


Lot, Block Number, or legal description of Property Bill 1 Lot 5B Angel Island

To be built by: Owner Square feet absorption area. 200 sq ft.

Septic Tank Size 750 minimum # of bedrooms 1 Water Supply Owner Well

Description of Absorption Area: Dig a bed 20 feet x 10 feet x 2½-3' deep according to the 1st layout and bed description

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



NOTE - See attached sheet for bed description

Soil: Rocky

Issued by Ron Anderson

Inspected by

Date 8-30-76

BILL LAKE