SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Phone _____

Date 10-14-75

Property Owner Robert L. Burke Address [redacted]


Lot, Block Number, or legal description of Property Block #1 Lot #2 Angel Island

To be built by: Johnson Square feet absorption area. 160 Sq ft.

Septic Tank Size 750 # of bedrooms 1 Water Supply Common well

Description of Absorption Area: Dig a bed 8'X20'X 2½-3' deep according to the attached description - The pipe should be level throughout the bed area.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Soil: sandy

Issued by Ron Anderson Inspected by _____

Date 10-15-75