# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 02/26/03 Expiration Date: 02/27/04

Property Owner: Cabinet Cedar Products, Inc. c/o: Zarach H. Epperson

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: Larry Bowman License No. 75

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe:

*Parcel Description*:

Legal: S29 T29 R33

Address or Location: Block 1 Lot 81 on Angel Island

*Approved Design Criteria*:

# Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 155 Linear Feet

***INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET IS REQUIRED !!***

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** Kendra J. Lind, R.S.

Closure Statement:

*I,* Larry Bowman *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* Larry Bowman *Date:* 16 June 03

*Title:* Owner B-K Land Development & Construction


**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-293-7781**

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

# LOT LAYOUT
# CABINET CEDAR PRODUCTS
# ZARACH EPPERSON
# BLOCK 1 LOT 81
# ANGEL ISLAND




SCALE: 1" = 30'