SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent June 6, 1978

Date June 2, 1978

Phone [redacted]

Property Owner Ray Carlson Address [redacted]


Lot, Block Number, or legal description of Property River Bend Block 1 Lot 50

To be built by: Contractor Square feet absorption area. 750 sq ft

Septic Tank Size 1000 gal # of bedrooms 2 Water Supply Public Well


Description of Absorption Area: Dig a bed 20 feet in length by 15 feet wide x 2½ - 3 feet deep according to lot layout. Serpac bed should be position as close to the parking area as possible

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Ditch Diagram

LOT LAYOUT



SOIL: Sandy clay w/ rock

SLOPE: 2-3%

Issued by [signature] Inspected by _____

Date _____