SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent ____

Date 7-29-77

Phone —

Property Owner Davis Address —


Lot, Block Number, or legal description of Property Lot 10 Block 1 Angel Island

To be built by: Johnson Square feet absorption area. 250 sq ft.

Septic Tank Size 1000 gal # of bedrooms 2-3 Water Supply Public Well


Description of Absorption Area: Dig a bed 25' x 10' x 2½-3' deep according to the lot layout sketch. Twelve inches of washed 1½" gravel is to be placed in the bottom of the seepage bed. the perforated pipe must be level in the bottom of the seepage bed.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

Lot Layout



Soil: sandy clay w/gravel

SLOPE: 2-4%

Issued by Ron Anderson

Inspected by Bull Lake Canal

Date 7-29-77