SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent [redacted]

Phone 3-5195

Date 7-2[redacted]

Property Owner Harold Day Address [redacted]

Lot, Block Number, or legal description of Property Lot 79 Arbel Island

To be built by: Hall Square feet absorption area. 160 sq.ft.


Septic Tank Size 750 gal # of bedrooms 1 Water Supply Community well

Description of Absorption Area: Dig a trench 2'x 20'x 2½-3' deep according to the attached discription -- the pipe should be laid throughout the bed area

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.

lot layout

Soil: sandy




Note: see attached sheet for drainage bed description.

Issued by Lon Anderson Inspected by T. G. Schultz

Date 7-29-75 8/27/75