LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/19/05 Expiration Date: 04/20/06

Property Owner: Robert H. Epperson c/o: Davis Surveying

Address: [redacted]

Telephone: (Home) (Work) [redacted]

Installer: License No.

____ New Installation __XX__ Existing System

_____ Repair __XX__ Replacement _____ Extension _____ Other

Describe:

Parcel Description:

Legal: S28 T29 R33

Address or Location: 14.7 Mile Post – Bull Lake Road

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 gallons Drainfield Size: 240 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LOT LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
LOT LAYOUT
TRACT 1F
IN THE NW 1/4 OF SECTION 28
TWP. 29 N., R. 33 W., P.M.M.
FOR: ROBERT H. EPPERSON DATE: DECEMBER 2004



SLOPE 4%

TRACT 1F
57.43 ACRES±

GRADIENT DIRECTION

LEGEND
- SOILS PROFILE
- PERCOLATION SITE
- PROPOSED WELL SITE
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-80' TRENCHES 10' APART
- REPLACEMENT SITE 3-80' TRENCHES 10' APART
- 200' MIXING ZONE

REPLACEMENT OF EXISTING
SEPTIC TANK & DRAINFIELD SITE

28

SCALE
1 INCH = 300 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 2/15/05	
DRAWN BY: MDM	FILE: T29R33S28.DWG