LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/20/2009 Expiration Date: 08/21/2010

Property Owner: Nicholas Garinger c/o:

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: Larry Bowman License No. 75

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: 2-bedroom dwelling & detached garage with lavatory (3-bedroom equivalent)

Parcel Description:

Legal: S20 T29 R33

Address or Location: Lot 69 in Block 1 of Angel Island 150 Halo Drive

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 225 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, Kathi Hooper *, have ~~inspected~~ reviewed this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 5-26-23

Title: Director


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT



5/22/23

I Mont Peters with Rocky Mountain Radar did verify to the best of my ability that there is a leach field on this lot. The lines are approx. 45ft long and there are five lines, 7ft apart. This field is per the design. This was prefored by Ground Penetrating Radar

Mont Peters

M & H Services
Cecil McDougall
275 Log Cabin Rd • Troy, MT 59935
(406) 295-9570
cecil321@live.com

"Your # 2 is our #1"

Septic Tank Pumping Portable Toilet Rentals

Invoice No: 04252023

To: Dhana Nelson
406-871-8765

Date: 04/25/2023

Location: 152 and 186 Halo Dr,
Troy, MT

Septic Tank Pump on 04/24/2023 Excavating 3 hours	@	$ 310.00 $ 240.00
System is in good working order Liquid level at correct level (no cracks in tank) 1,000 gallon concrete tank Baffles in good shape Filter in outlet side of tank Cleaned filter		
	Total:	**$ 550.00**

Thank you for doing business with us