LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 6/1/2009 Expiration Date: 6/1/2010

Property Owner: Tom Georgiou c/o: Phillip Coblentz

Address: [redacted]

Telephone: (Home) (Cell)

Installer: Phillip Coblentz License No.

Proposed Work: (Check One) _____ New Installation __X__ Existing System

_____ Repair _____ Replacement __X__ Extension _____ Other

Describe: Adding one 500 gallon tank and one 65-foot leach line to existing 2004 Beasley permit for expansion.

Parcel Description:

Legal: SW ¼ S29 T29N R34W

Address or Location: Lot 10 Bull lake Estates

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 Gallons Drainfield Size: 260 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Lori Kelley-Bowe, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:*

Title:

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

