SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 6-1-79

Phone [redacted]

Property Owner Barney Gerger Address [redacted]


Lot, Block Number, or legal description of Property Lot 79, Block 2

To be built by: M. Warrington Square feet absorption area. 300

Septic Tank Size 1000 gal # of bedrooms 2 Water Supply Community


Description of Absorption Area: Dig a ditch 150' long x 2½-3' deep x 2' wide according to lot layout and Lith Lagoon. Slope of pipe should not exceed a 1% drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Ditch Diagram

LOT LAYOUT



Soil: tight silt

Slope: 1-2% Slope

Issued by John W Peterson Inspected by _____

Date 6-1-79