File

OPTION 1

NEW

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 6-12-80

Phone [redacted]

Property Owner Harold Jenks Address [redacted]

Lot, Block Number, or legal description of Property Lot 2 Block 5 Angel Island

To be built by: M. Warrington Square feet absorption area. 260

Septic Tank Size 750 gal (MW) # of bedrooms 2 Water Supply Community Sy

Description of Absorption Area: Dig a ditch 130' long x 2½-3' deep x 2' wide according to lot layout. Grade ditch diagram. Slope of pipe should not exceed a 1% drop.


Sketch: Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



SOIL: Silty loam

SLOPE: 5-10%

LOT LAYOUT



Issued by John W Peterson, RS Inspected by _____

Date 6-12-80

Please let me know which option you chose. -John