SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent 8-24-77

Date 8-23-77

Phone [redacted]

Property Owner MORRIS & EDITH KAIR Address [redacted]


Lot, Block Number, or legal description of Property LOT 53 BLOCK #1 ANGEL ISLAND

To be built by: WARRINGTON JOHNSON Square feet absorption area. 320 sq ft

Septic Tank Size 1000 gal # of bedrooms 3 Water Supply Public Well


Description of Absorption Area: Dig a bed 10' x 32' x 2½-3' deep according to lot layout and bed diagram. See attached sheet for seepage bed instructions.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

Lot Layout



- NOTE - THE SEEPAGE BED LOCATION WILL DEPEND ON WATER LINE PLACEMENT.

Soil: Sandy clay

SLOPE: 0-1%

Issued by Ron Anderson Inspected by _____

Date 8-23-77

SEEPAGE BED DIAGRAM

SCALE: 1" = 2'

