NEW

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Phone _____

Date 7-21-80

Property Owner Don Lockey Address [redacted]


Lot, Block Number, or legal description of Property Bl 1 Lot 7& Angel Island

To be built by: M. Warrington Square feet absorption area. 450

Septic Tank Size 1000 gal # of bedrooms 3 Water Supply Community

Description of Absorption Area: Construct a seepage bed as per lot layout and attached diagram. Slope of pipe in bed should be 0%

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.




DITCH DIAGRAM

SOIL: Silty Clay

SLOPE: 1%

Lot Layout



OPTION 2

Issued by John W. Peterson, R.S. HACO DRUG Inspected by _____

Date 7-21-80