SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 3-30-79

Phone [redacted]

Property Owner Wendell Moges Address [redacted]


Lot, Block Number, or legal description of Property Block 3, Lot 11 - Angel Island

To be built by: M. Warrington Square feet absorption area. 220

Septic Tank Size 750 gal # of bedrooms 2 Water Supply Community


Description of Absorption Area: Construct a ditch 110' long x 2½-3' deep x 2' wide according to ditch diagram and lot layout. Slope of pipe should not exceed a 1% drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.




Ditch Diagram

LOT LAYOUT




Soil: tight silt

Slope: 0%

Issued by Johnny Peterson Inspected by _____

Date 3-30-79

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 3-30-79

Phone [redacted]

Property Owner Wendell Magee Address [redacted]


Lot, Block Number, or legal description of Property Block 3 Lot 11 - Angel Island

To be built by: M. Warrington Square feet absorption area. 450

Septic Tank Size ~~1000 gal~~ 750 gal # of bedrooms 2 Water Supply Community


Description of Absorption Area: Construct a seepage bed according to the lot layout and attached sheet. Drainpipe should have no slope.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.




Ditch Diagram

LOT LAYOUT




Soil: tight silt

Slope: 0%

Issued by John W Peterson Inspected by _____

Date 3-30-79