LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/8/2007 Expiration Date: 8/8/2008

Property Owner: Amy & Charles Mattia c/o:

Address: Lot 20 Bull Lake Estates

Telephone: (Home) (Work) [redacted]

Installer: License No.

Proposed Work: (Check One) __X__ New Installation ____ Existing System

_____ Repair ____ Replacement _____ Extension _____ Other

Describe: Sand-lined bottom & side wall trenches required. Using "infiltrator" chambers-25% reduction in drainfield size. System will require a lift station.

Parcel Description:

Legal: S29 T29N R33W

Address or Location: Lot 20 Bull Lake Estates

Approved Design Criteria:

Bedrooms: 5 Septic Tank Size: 1500 gallons Drainfield Size: 252 Linear Feet

Lift-station Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SAND-LINED SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Lori Kelley-Bowe, S.I.T.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:*

Title:

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT
AMY & CHARLES MATTIA
LOT 20
BULL LAKE ESTATES

