LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 5/16/2016

Property Owner: Richard McElmurry

Mailing Address: [redacted]

Telephone: (Home) [redacted] (Work)

Name of Person Who Installed System Being Reviewed: Keith Mack

Type of System Work Reviewed:

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 40' pressure dosed laterals in 3' wide trenches

Property Description:

Legal: S20 T29 R33

Address or Location: Angel Island Lot 47B

Reviewed Design Components:

Wastewater Flows: 225gpd Sewer Lines: Septic Tank: 1000gal Effluent Filter: Yes

Dosing or Lift Tank: 500gal Drainfield Size: 360sqft Drainfield Construction: Drain Tile

Hydraulic Function: NC

Comments: System sized for two bedroom house per COSA 27-70-480.

System Review Documentation Statement:

I, JAKE MEATES R.S., *have inspected/reviewed the components of this system as listed above and found it to be in compliance with the sizing, construction, orientation and operating requirements of Chapter 17, Subchapter 9 A.R.M., Circular DEQ-4 and Lincoln County Wastewater Regulation #3.*

Signed: _____ *Date:* 5/16/2016

Title: LOCAL SANITARIAN / ENVIRONMENTAL HEALTH SPECIALIST

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment system. It is merely a statement of affirmation that the Department has conducted an on-site review of an otherwise illegal system and found it to be in compliance with all applicable requirements for that system. This affidavit effectively removes the illegal installation status on this system.

DISCLAIMER

This affidavit of review is not a guarantee by the Department that the system will continue to function properly for any prescribed period of time.

LOT LAYOUT

