SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent May 4, 1978

Phone _____ Of Coun Jail

Date MARCH 20 1978

Property Owner DONALD MICHAUD Address [redacted]


Lot, Block Number, or legal description of Property BLOCK 5 LOT 17 ANGLER ISLAN

To be built by: J F W Square feet absorption area. 500 sq ft.


Septic Tank Size 1000gal # of bedrooms 3 Water Supply Common Well

Description of Absorption Area: Dig a ditch or bed 10' x 50' x 2½-3' deep according to lot layout and ditch diagram.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM



Soil: Sandy loam w/ gravel

SLOPE: 3-5%

Issued by Ron Anderson Inspected by _____

Date March 20, 1978