LINCOLN COUNTY
SEPTIC SYSTEM PERMIT NO. NEW

ISSUED TO: Louis OSTERBERG DATE: 5-6-87

ADDRESS: [redacted] PHONE: [redacted]

ISSUED BY (sign.) John W Peterson, RS

INSPECTION BY (sign.) _____ DATE: _____

(You must notify the Department of Environmental Health a minimum of 8 working day hours before backfilling the septic system, so that it can be inspected.)

CONTRACTOR: _____

DESCRIPTION OF SYSTEM:

LOCATION OF PROPOSED SYSTEM Lot 8 Peak Tracts Bull Lake

SEPTIC TANK 1,000 gal. ABSORPTION AREA: 200 ft²

SEWAGE DISCHARGE ~ gal/day NO. OF BEDROOMS Camper Dump Station

WATER SUPPLY SOURCE Well SOIL Sandy Clay SLOPE 0%

DRAINFIELD INSTRUCTIONS: Dig a ditch 100' long x 2½-3' deep x 2' wide according to lot layout & septic system regs. Slope of pipe should not exceed a 1% drop

SKETCH OF LOT LAYOUT:

