SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 9-13-79

Phone [redacted]

Property Owner LUDWIG PRUCKER Address [redacted]

Lot, Block Number, or legal description of Property Lot 6, Block 2 - Angel Island


To be built by: M. Warrington Square feet absorption area. 680

Septic Tank Size 1000 gal # of bedrooms 8 Water Supply Community


Description of Absorption Area: Dig a ditch 340' long x 2½-3' deep x 2' wide according to lot layout and ditch diagram. Slope of pipe should not exceed a 1% drop.

*Note: State Min. = 85 ft² / bd of absorption area.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM



graywater system approved 9-1985 JWP

THIS PERMIT REPLACES PERMIT DATED 5-9-79 JWP

Soil: Silty Clay

SLOPE: 0%

Issued by John W. Peterson Inspected by _____

Date 9-13-79