LINCOLN COUNTY SEPTIC SYSTEM PERMIT

ISSUED TO: Rik Reweerts PHONE: [redacted]

ADDRESS: [redacted] CONTRACTOR: Robertson

ISSUED BY (sign.): John W Peterson RS DATE: 5-28-92

INSPECTION BY (sign.): _____ DATE: _____

*PLEASE NOTE: The Lincoln County "On-site Sewage Disposal Regulation" does not conform with all requirements of the Montana State "Sanitation in Subdivision Act". Therefore, septic systems permitted under the county regulation may not be approvable for the purpose of future land division health reviews.

You must notify the Department of Environmental Health a minimum of 8 working hours before backfilling the septic system, so that it can be inspected. Reweerts/Ward occ sale

LOCATION OF PROPOSED SYSTEM: Lot 4 Sec 32 T29 R33 Bull Lk

SEPTIC TANK: 1000 gal. ABSORPTION AREA: 260 ft²

SEWAGE DISCHARGE: ~ gal/day No. OF BEDROOMS: 1

WATER SUPPLY SOURCE: Shared well SOIL: Coarse to Med Sands SLOPE: 0%

INSTRUCTIONS: Drainfield Dig a ditch 130' long x 2½-3' deep x 2' wide according to lot layout & Septic System regulations Slope of pipe should not exceed a 1% drop

SKETCH OF LOT LAYOUT:

