SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 5-9-79

Phone [redacted]

Property Owner Martin Riedlinger Address Rt 2 Troy


Lot, Block Number, or legal description of Property Lot 55 Block ~~55~~ 1 - Angel Island

To be built by: L & L Square feet absorption area. 200


Septic Tank Size 750 gal # of bedrooms 2 Water Supply Community

Description of Absorption Area: Dig a ditch 100' long x 2½-3' deep x 2' wide according to lot layout and ditch diagram. Slope of pipe should not exceed a 1% drop.

Sketch: Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Ditch Diagram



Soil: gravelly silt

Slope: 1%

Issued by John W Peterson Inspected by _____

Date 5-9-79