NEW

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent ✓

Date 10-28-80

Phone [redacted]

Property Owner Paul Seifert MD Address [redacted]


Lot, Block Number, or legal description of Property Block 1 Lot 23 Angel Island

To be built by: M. Warrington Square feet absorption area. 450

Septic Tank Size MIN. 1000 gal. # of bedrooms 2 Water Supply Community


Description of Absorption Area: Construct a seepage bed according to lot layout and attached diagram. Slope of pipe in bed should be 0% grade.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

Lot Layout



SOIL: Sandy Silt.

SLOPE: 0% at seepage bed

Issued by John W. Peterson, R.S. Inspected by _____

Date 10-28-80