LINCOLN COUNTY SEPTIC SYSTEM PERMIT Replaces permit issued 4/30

ISSUED TO: Kurt Spencer PHONE: [redacted]

ADDRESS: [redacted] CONTRACTOR: Self / Robertson

ISSUED BY (sign.): John Peterson, R.S. DATE: 5-13-92

INSPECTION BY (sign.): DATE:

*PLEASE NOTE: The Lincoln County "On-site Sewage Disposal Regulation" does not conform with all requirements of the Montana State "Sanitation in Subdivision Act". Therefore, septic systems permitted under the county regulation may not be approvable for the purpose of future land division health reviews.

You must notify the Department of Environmental Health a minimum of 8 working hours before backfilling the septic system, so that it can be inspected. Reuert / Ward Occ Sale 0.66 Ac

LOCATION OF PROPOSED SYSTEM: Gov't Lot 4 Sec. 32 T29 R33 Bull Lake

Proposed
SEPTIC TANK: 1000 gal. ABSORPTION AREA: 240 ft²

SEWAGE DISCHARGE: ~ gal/day No. OF BEDROOMS: 1

WATER SUPPLY SOURCE: Shared well SOIL: Sandy SLOPE: 4%

Drainfield
INSTRUCTIONS: Dig a ditch 130' long x 2½-3' deep x 2' wide according to lot layout & septic system regulation. Slope of pipe should not exceed a 1% drop

SKETCH OF LOT LAYOUT:

