NEW

LINCOLN COUNTY
SEPTIC SYSTEM PERMIT No. _____

Issued to: Stanley & Joyce Stoker Phone: [redacted]

Address: [redacted]

Issued by: John W Peterson R.S. Date: 10/28/81

Inspected by: _____ Date: _____

Description of System:

Location of Proposed System: Angel Island Block 1 Lot 48


Septic Tank 1000 gal. Absorption Area: 450 ft²

Sewage Discharge — gal/day No. of bedrooms 2-3

Water Supply: Community Well Soil type: Rocky Silt Slope: 0%

Instructions: Construct a seepage bed as per lot layout and attached diagram. Bottom of bed is at 0% grade.

Ditch Diagram



Sketch of Lot layout:

