9/96 R

PERMIT

Issue Date: 04/04/95 Expiration Date: 04/05/96

Property Owner: James P. Tomlin c/o: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: OBERWALDT License No. 2

XX New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: Lot 34, Block 1 Angel Island S 1/2 S20 & N 1/2 S39 T29 R33

Address or Location: 628 Halo Drive Troy, MT

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: ~~225~~ 195 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: *ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.*


Issued By: [signature] CS

Closure Statement:

I, TERRY J. OBERWALDT, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: [signature] *Date:* 9/31/96

Title: V.P.


199.05' N 87deg 46'15" W
117.76' N 00deg 19'52" E
211.12' N 76deg 45'17" E
SEPTIC SETBACK LINE
LOT #34
AREA RESERVED FOR REPLACEMENT
14'
65'
7'
7'
20'
24'
10' MIN.
10' MIN.
10'
SEPTIC TANK
D-BOX
N
LOT LAYOUT
JAMES P. TOMLIN
B 29'6" 29' 6" 25' 8" 20' 2" 14' 0"
A 11'6" 13'6" 15'9" 20'4" 40' 8"
4x4 y
4x2 y
INLET
OUTLET
D BOX