SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Phone None

Date June 18, 1974

Property Owner Ed Vance Address RT 2 - TROY, MO.


Lot, Block Number, or legal description of Property LOT 5 ¼ mile beyond halfway house

To be built by: Self Square feet absorption area. 200'

Septic Tank Size 750 # of bedrooms 2 Water Supply Well

Description of Absorption Area: Dig a ditch 3' wide x 2½' deep x 70' in length following the lot layout and drain ditch diagram

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Issued by T. S. Schultz Inspected by _____

Date _____