PERMIT

Issue Date: 9-10-97 Expiration Date: 9-10-98

Property Owner: JOHN AND SANDY WAGNER

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: JOHN RIEWOLDT License No. 10

✓ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: YAAK RIVER ESTATES LOT 4

Address or Location: HES 433 AND Sec. 3 T35N R32W

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 160 lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: _____

Issued By: John Peterson, RS.


Closure Statement:

I, John Riewoldt have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: John Riewoldt *Date:* Sept 11 97

Title: installer

LOT LAYOUT


N
1"=50'
LOT 4
ROAD EASEMENT
80'
DRAIN FIELD
10'
Septic Tank
House
Replacement Area
100'
EXISTING well
Revised 9/12/97