SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 5-9-79

Phone [redacted]

Property Owner Marshall Warrington Address [redacted] (Angel Island)


Lot, Block Number, or legal description of Property SE¼ Sec 8 T 29N R 33W

To be built by: Self Square feet absorption area. 300'

Septic Tank Size 1000 gal # of bedrooms 2 Water Supply proposed well


Description of Absorption Area: Dig a ditch 150' long x 2½-3' deep x 2' wide according to lot layout and ditch diagram. Slope of pipe should not exceed a 1% grade.

Sketch: Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Ditch Diagram

LOT LAYOUT



SOIL: Gravelly Silt

SLOPE: 0%

Issued by John W Peterson Inspected by _____

Date 5-9-79