LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/27/05 Expiration Date: 12/28/06

Property Owner: Geraldine West c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: Dennis Riedlinger License No. 23

__XX__ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: Installation of an at-grade, pressure-dosed system is required.

Parcel Description:

Legal: NE-1/4 S29 T29 R33

Address or Location: Lot 5 of Feak Tracts

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1000 gallons Drainfield Size: 195 Linear Feet

Dosing Tank Size: 500 gallons

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL AT-GRADE, PRESSURE-DOSED SYSTEM ACCORDING TO PLAN DETAILS LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kendra J. Lind, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
LOT LAYOUT
LOT 5 OF FEAK TRACTS (C.O.S. 29)
IN SECTION 29
TWP. 29 N., R. 33 W., P.M.M.
FOR: GERALDYNE WEST DATE: MAY 2004

EQ No. 06-1076

RECEIVED
OCT 04 2005
MT DEQ PUBLIC WATER & SUBDIVISIONS BUREAU



APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Reviewer 11/10/05
Date
EQ#06-1076

LOT 5
STANDARD SIDEWINDER
INFILTRATOR AT GRADE SYSTEM
3-65' TRENCHES
7' APART

SCALE
1 INCH = 200 FT.

Davis Surveying Inc.
TROY MONTANA, (406)295-5441

DATE: 5/16/04	
DRAWN BY: MTL	FILE: T29R33S29.DWG