Permit # 24-9683

LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/12/2024 Expiration Date: 09/11/2025

Property Owner: Allyson Properties LLC.

Mailing Address: 782 Sheldon Flats Rd. Libby, MT 59923

Installer: Terry Oedewaldt License #: 2

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system for 1 Bedroom House.

Parcel Description:

Legal: MOUNTAIN VIEW PARK, S03, T30 N, R31 W, BLOCK 5, LOT 2-3

Property Address: 166 Park St., Libby, MT 59923 Assessment Code: 9683

DEQ COSA: EQ# Date:

Approved Design Criteria: Installation of new gravity system for 1 Bedroom House with 2 Laterals @ 35' with reduction for chambers.

# of Bedrooms: 1 Septic Tank Size: 1000 gallons Trench Width: 24"

# of Laterals: 2 Length of Laterals: 35' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 2/28/25

__V__ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

Burr Ave
65 Burr Ave.
166 Park St
50 ft
10ft.
Drain Field
10ft.
Replacement
180 ft.
130 ft.
120
56-4175-03-1-10-03-0000
56-4175-03-1-10-02-0000
Drain Field
Shared well
90 ft.
Proposed well
30 ft
well
208 Park St.
120 ft
56-4175-03-1-10-04-0000
Drain Field
Park St
56-4175-03-1-06-06-0000
56-4175-03-1-06-07-0000
56-4175-03-1-06-08-0000
56-4175-03-1-06-09-0000
56-41
06-1