NEW

file

SEPTIC TANK PERMIT for LINCOLN COUNTY

Permit Sent _____

Date 6-5-80

Phone [redacted]

Property Owner Conn - Johnson Address [redacted]


Lot, Block Number, or legal description of Property Block 5 Lot 4 Angel Island Bulk

To be built by: — Square feet absorption area. 450

Septic Tank Size 1000gal # of bedrooms 3 Water Supply Community


Description of Absorption Area: Dig a ditch 225' long x 2½-3' deep x 2' wide according to lot layout and ditch diagram. Slope of pipe should not exceed a 1% drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

Lot Layout



N

SOIL: Sandy Silt

SLOPE: 2%

Bethel Drive

Issued by John W. Peterson, R.S. Inspected by _____

Date 6-5-80