LINCOLN COUNTY HEALTH DEPARTMENT Permit # 25-52563
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 01/09/2025 Expiration Date: 01/08/2026

Property Owner: Kelly DeLaHunt/Traci Steen

Mailing Address: [redacted]

Installer: Franklin Fifield License #: 198

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new pressure dosed system for 1 Bedroom House.

Legal: ITSAVIEW 2, S21, T31 N, R33 W, ACRES 3.34, LOT 4B PM 7168

Property Address: 144 Itsaview Ln., Troy, MT 59935 Assessment Code: 52563

DEQ COSA: E.Q.# 12-1364 Date: 1/3/25

Approved Design Criteria: Installation of new pressure dosed system for 1 Bedroom House with 2 Laterals @ 45' with reduction for chambers.

# of Bedrooms: 1 Septic Tank Size: 1000/500 gallons Trench Width: 36"

# of Laterals: 2 Length of Laterals: 45' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, RS

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 3/17/25

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

SJ

REVISED LOT LAYOUT

ITSAVIEW Lot 4B


NW 1/4, SEC 21, T31N, R33W PM MT

LINCOLN COUNTY, MT

EQ 12-1364

NORTH

APPROVED
Montana Department of Environmental Quality
Reviewer 11/03/2025 Date
EQ # 12-1364





Scale: 1"= 79'

RECEIVED
DEC 23 2024
MT DEQ PUBLIC WATER & SUBDIVISIONS

Roadway Ditch Diagram

Swale Cross Section





NOTES:
1. THERE ARE NO DRAINFIELDS OR WELLS WITHIN 100' OF THE PROPERTY BOUNDARY OTHER THAN SHOWN.

Keeler Creek Construction, LLC
License #198

December 22, 2024