LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/11/03 Expiration Date: 04/12/04

Property Owner: Donald K. Ennis c/o:

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: John Kampfe License No. 15

____ New Installation ____ Existing System

____ Repair ___✓___ Replacement ____ Extension ____ Other

Describe:

Parcel Description:

Legal: S20 T29 R33 Lot 4, Block 5 --- Angel Island

Address or Location: 880 Halo Drive

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 150 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kendra J. Lind, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: John Kampfe *Date:* 4-28-03

Title: Installer

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

DONALD K AND JANICE K ENNIS
10804 NE 182ND ct
Bothell, WA. 98011

LOT 4 BLOCK 5



HALLO DRIVE