LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
Declaration of Unpermitted Wastewater Treatment and Disposal System

System B

Property Owner(s): Harold A. Etienne

Property Address: 1421 Iron Creek Rd (according to Lincoln Co. GIS)
Troy MT 59935

Legal Description of the Property: 31 0N 34 0W 24 SE4 COS 2522

Wastewater Treatment and Disposal System Description

Year Installed: 1984

Installed by: Dennis Walton, Contractor

Have there been repairs or alterations to the tank or drainfield since the original installation? NO

Septic Tank:

Size: 1000 gallon Material: Concrete Date Last Pumped: 11/19/24

Attach receipt/report from most recent septic tank pumping.

Drainfield size, construction and other information: 2x 55' long x 3' wide drain field legs, filled with washed rock and containing standard perforated sewer pipe.

Provide lot layout including location of property boundaries, septic tank, drainfield, and well.

I (~~We~~), Harold A. Etienne, attest that the above information is true and correct to the best of my (our) knowledge.

Signature of Property Owner: Harold A. Etienne Date: 1-21-2025

Signature of Property Owner: _____ Date: _____

SV

M & H Services
Cecil McDougall
275 Log Cabin Rd • Troy, MT 59935
(406) 295-9570
cecil321@live.com

"Your # 2 is our #1"

Septic Tank Pumping Portable Toilet Rentals

Invoice No: 7361

To: Dave Etienne
Iron Creek Rd
Troy, MT 59935

Date: 11/19/2024

1 Septic Tank Pump Excavating	@	$ 340.00 $ 100.00
Concrete tank Baffles in good shape Correct liquid level System is in good working order		
	Total:	**$ 440.00**


Terms: Due within 10 days of bill date
1.5 % interest monthly &/or $ 6.00 rebilling charge will be assessed on past

Thank you for doing business with us

Cecil McDougall

Septic System "B" Layout
1421 Iron Creek Road
Troy, MT 59935

Location Map of Septic Systems on Parcel



3 Bedroom Manufactured Home
Constructed 1983 (set up 1984)

~ 10'

1000 gallon concrete
Septic Tank
Installed 1984

55' x 3' drainfield

55' x 3' drainfield

Soil Type: Sandy Loam/Sandy-clay loam per Ken Davis soil profile 2023

Drain Fields consists of 3' wide trenches filled with washed river rock with embedded standard perforated sewer pipe

0 10 20 ft

Drafted JEE 1/2025