LINCOLN COUNTY HEALTH DEPARTMENT Permit #24-10183
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/12/2024 Expiration Date: 12/11/2025

Property Owner: Owen Fifield

Mailing Address: [redacted]

Installer: Franklin Fifield License #: 198

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new pressure dosed elevated sand mound for Shop with bathroom sized as 1 Bedroom.

Legal: ERICKSON PLAT, S32, T31 N, R31 W, BLOCK 13, ACRES 0.34, PARCEL B OF LOT A9B

Property Address: 71 Crossover Rd., Libby, MT 59923 Assessment Code: 10183

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new pressure dosed elevated sand mound for Shop with bathroom sized as 1 Bedroom to replace previously approved system that was never installed.

# of Bedrooms: 1 Septic Tank Size: 1000/500 gallons Trench Width:

# of Laterals: ESM Length of Laterals: ESM Trench Depth:

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

This permit is not finalized until the system is inspected and the closure statement is signed.


This permit is not a guarantee that the system will function properly for a prescribed period of time.

SV

Lot Layout
71 Crossover Rd
Libby, Montana 59923

Owner: Owen Fifield
415 W. 2nd St
Libby, MT 59923

Geocode: 56-4283-32-3-06-19-0000



Installed by:
Keeler Creek Construction
License: 198