Permit # 23-5778

LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/14/2023 Expiration Date: 09/13/2024

Property Owner: Steve and Valerie Haarstick

Mailing Address: [redacted]

Telephone: 406-295-4825 E-mail: [redacted]

Installer: Tally Hoe License #: 1

Approved Work: (Check One) ☐ New Installation ☒ Existing System

☒ Replace Drainfield ☒ Replace Tank ☒ Extension

Describe: Installation of replacement tank and drainfield.

Parcel Description:

Legal: IRON CREEK ESTATES, S25, T31 N, R34 W, ACRES 1.3, LOT 3 IN N2NESW 5778

Property Address: 2444 Iron Creek Rd. Troy, MT 59935 Assessment Code: 5778

DEQ COSA: EQ# 27-79-K2749 Date: 10/01/79

Approved Design Criteria: Installation of replacement tank and drainfield with 5 laterals @ 72'.

# of Bedrooms: 3 Septic Tank Size: 1000 Trench Width: 24"

# of Laterals: 5 Length of Laterals: 72' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, SIT

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:


This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ Date: 10-1-23

_____ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


N
Slope > 3%
Still used leach line
dry well not used
3 Beds
Power wires to house
well
Phone line
Iron R d