LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Permit #24-889

Issue Date: 09/05/2024 (Renewal) 2/21/2023 Expiration Date: 09/04/2025

Property Owner: Bryon Hoerner

Mailing Address: [redacted]

Installer: Jeremy Wetzel License #: 204

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Pressure dosed system for 3 Bedroom House.

Parcel Description:

Legal: Crystal Lakes Unit 1, Lot 67, S19 T35N R25W, 0.461 acres

Property Address: Birch Lane, Eureka Assessment Code: 889

Approved Design Criteria: Installation of new pressure dosed system for 3 Bedroom House with 3 Laterals @ 67'.

# of Bedrooms: 3 Septic Tank Size: 1000/500 gallons Trench width: 36"

# of Laterals: 3 Length of Laterals: 67' Trench Depth: 24 - 36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 11/20/24

✓ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

Lot 67

Water
Drive
Power
Parking
Gravel
26'
Water line
2 or 3%
N
48°
Garage
House
Tank
Drain field
10'
Back up Drain field
20'
24'