LINCOLN COUNTY
SEPTIC SYSTEM PERMIT NO. NEW - TRL

ISSUED TO: William Mayes DATE: 4-6-84

ADDRESS: [redacted] PHONE: [redacted]

ISSUED BY (sign.) John Peterson, R.S.

INSPECTION BY (sign.) _____ DATE: _____

(You must notify the Department of Environmental Health a minimum of 8 working day hours before backfilling the septic system, so that it can be inspected.)

CONTRACTOR: _____

DESCRIPTION OF SYSTEM:

LOCATION OF PROPOSED SYSTEM Angel Island Block 3 Lot 33

SEPTIC TANK Min. 750 gal. ABSORPTION AREA: 300 ft²

SEWAGE DISCHARGE - gal/day No. OF BEDROOMS 2

WATER SUPPLY SOURCE Community SOIL Gravelly, Sandy Loam SLOPE ½ %

INSTRUCTIONS: Dig A Ditch 150' Long x 2½-3' Deep x 2' Wide According To Lot Layout & Septic System Reg's. Slope of Pipe should not exceed A 1% Drop.

SKETCH OF LOT LAYOUT:

