LINCOLN COUNTY HEALTH DEPARTMENT Permit #25-53056
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 02/06/2025 Original Permit Issue Date: 11/7/2007

Property Owner: Barry Stidham

Mailing Address: [redacted]

Installer: Homeowner License #:

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system for 3 Bedroom House.

Legal: S36, T34 N, R25 W, ACRES 38.02, N2NW

Property Address: 283 Sunday Creek, Stryker, MT 59933 Assessment Code: 53056

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new gravity system for 3 Bedroom House with 3 Laterals @ 85'.

# of Bedrooms: 3 Septic Tank Size: 1000 gallons Trench Width: 36"

# of Laterals: 3 Length of Laterals: 85' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 2/6/25

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

LOT LAYOUT NOTES:
NO KNOWN POTENTIAL SOURCES OF CONTAMINATION WITHIN 500' .

NO WELLS OR DRAINFIELDS OR MIXING ZONES WITHIN 100' OF PROPERTY LINES.

NO WETLANDS ON OR NEAR THE PROPERTY.

DRAINFIELDS ARE GRAVITY FED, CONSTRUCTED PER CIRCULAR DEQ 4.

LINCOLN COUNTY MONTANA


LOT LAYOUT: SUNDAY CREEK RANCH:

BOOK 333 PAGE 448

In the NW 1/4 of Section 36, Twp. 34 N., R. 25 W., P.M.M.

For: Barry G. Stidham & Robert T. White

Date: August 2023



Graphic Scale:

400 0 200 400

1 inch = 400 ft.

Davis Surveying Inc. TROY MONTANA, (406)295-5441	
DATE: 10-06-23	
DRAWN BY: SM	FILE: t342536sw.dwg