SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent June 6, 1976

Date June 2, 1976

Phone _____

Property Owner Juan Stine Address _____

Lot, Block Number, or legal description of Property Lot 9 Block 2 Arrec Estates


To be built by: Warrington Square feet absorption area. 300 sq ft

Septic Tank Size 750 gal # of bedrooms 2 Water Supply Public well

Description of Absorption Area: Dig a bed at least 20 feet in length x 2½-3' deep x 15 feet wide according to lot layout. Perforated pipe in bed should be level throughout. I would recommend expanding the bed to 400 sq ft to insure longevity of the system.


Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.

LOT LAYOUT



DITCH DIAGRAM

CHERUB LAKE



SOIL: Sandy silt

SLOPE: 2-4%

Issued by Ron Anderson Inspected by _____

Date June 2, 1976