Permit #24-59710

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/18/2024

Expiration Date: 12/17/2025 (4th RENEWAL)

Property Owner: Scott & Debbie Welch

2nd.Renewal Prior Owner Dorothy Eisenman

Address: [redacted]

3rd(Renewal)

Installer: Licensed Lincoln County Required

License No.

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension __XX__ Other (RENEWAL)

Describe: Five 96' Laterals using chambers.

Parcel Description:

Legal: CYHAWK ESTATES, S29, T36 N, R27 W, ACRES 11.367, LOT 8 PM 7174

Address or Location: 266 Kenny Road Rexford, MT 55930

Geo/Assessors code: 0000059710

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 gallons Drainfield Size: 480 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, R.S.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

_____


NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2444

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV


501.73'
MATCH LINE
624.76'
100'
STORMWATER
DETENTION
EASEMENT
112.17'
132.00'
86.60'
82.42'
311.02'
374.63'
29.10'
41.66'
157.00'
2%
STORMWATER
DETENTION
EASEMENT
255.85'
63.10'
63.35'
106.82'
100'
Lot 8
11.367 acres
586.26'
STORMWATER
DETENTION
EASEMENT
MATCH LINE
465.75'
749.03'